



## Declaration of Performance

### Rectangular smoke control damper SDR2-M – Multi Compartment

1. Product type	Rectangular Smoke control multi-blade damper – Multi Compartment Min. 180x180 mm Max. 1500x800 mm EI 120 (h <sub>od</sub> -V <sub>ed</sub> – i <-> o)S1000C <sub>mod</sub> Hot 400/30 MA/AA Multi
2. Intended use/es	Smoke control damper that is used in smoke control systems, in multi-compartment applications, either up to 600°C or at fire temperatures.
3. Manufacturers	ID 26718405
4. Authorised representative	PAVUS – Notified Body 1391 Prosecká 412/74, 190 00 Praha 9 - Prosek
5. System/s of AVCP	System 1
6a. Harmonised standard	EN 12101-8 – CE certificate (EN 1366-10 – Test standard) (EN 13501-4 – Classification standard)
6a. Notified body	PAVUS, a.s.
6b. European Assessment Document	1391-CPR-2021/0044
7. Declared performance/s	See table below.
8. Appropriate or specific Technical Documentation	N/A

7. Declared performance/s			
Essential characteristic	Requirement clauses in EN 12101-8	Findings	Conformity assessment
Nominal activation conditions/sensitivity	cl. 4.2.1.3	Closing / opening during the test at the right time	Conforms
Response delay (response time)	cl. 4.2.1.4	< 60 s	Conforms
Operational reliability	cl. 4.4.2.2	C10000, C <sub>mod</sub>	Conforms
Fire resistance – integrity	cl. 4.1.1 a)	E 120, E 90 < 360 m <sup>3</sup> /(h.m <sup>2</sup> )	Conforms
Fire resistance – insulation	cl. 4.1.1 b)	EI 120, EI 90	Conforms
Fire resistance – smoke leakage	cl. 4.1.1 c)	EI 120 S1000/1500, EI 90 S1000/1500 <200 m <sup>3</sup> /(h.m <sup>2</sup> )	Conforms
Fire resistance – mechanical stability	cl. 4.1.1 d)	120/90 min	Conforms
Fire resistance – maintenance of cross-section	cl. 4.1.1 e)	120/90 min	Conforms
Fire resistance – high operational temperature	cl. 4.1.1 f)	HOT 400/30	Conforms
Durability of response delay	cl. 4.4.2.1	< 60 s	Conforms
Durability of operational reliability	cl. 4.4.2.2	C10000, C <sub>mod</sub> < 120 S	Conforms

This declaration of performance is issued under the sole responsibility of the supplier identified in this declaration.

Signed for and on behalf of the supplier by:

Authorised person:  
Torbjörn Bruzelius  
Strategic Product Manager Ventilation Products  
2021-04-12 Grevie, Sweden